



UQGS.S35734 Heat-automatic Fire Detectors

[Page Bottom](#)

Heat-automatic Fire Detectors

[See General Information for Heat-automatic Fire Detectors](#)**EUROFYRE LIMITED**

S35734

Unit C1 Knowle Village Business Park, Mayles Lane
Hampshire, PO17 5DY UNITED KINGDOM

Model No.	Type	Compatibility Restrictions	Contact Arrangement	Temp Range (°F)	Spacing (Ft)	
					Smooth Ceiling	to Wall or Partition
FLA100 (1)	HSC	D1	NO	129-212	35	17.5
FLD105	FT, HSC	None	NO	221	35	17.5
FLD105N	FT, HSC	None	NO	221	15	7.5
FLD68	FT, HSC	None	NO	155	35	17.5
FLD68N	FT, HSC	None	NO	155	15	7.5
FLD85	FT, HSC	None	NO	-	-	-
FLD88	FT, HSC	None	NO	190	35	17.5
FLD88N	FT, HSC	None	NO	190	15	7.5

D1 - Listing limited to specific system control unit. Information on compatible control unit indicated on installation drawing of control unit and/or detector.

HSC - Heat sensitive cable

FT - Fixed temperature

(1) - The Model FLA100 must be used with either FLAC or FLACPC and FLAEOL.

D1 - Listing limited to specific system control unit. Information on compatible control unit indicated on installation drawing of control unit and/or detector.

FT - Fixed Temperature

HSC - Heat sensitive cable

Last Updated on 2016-02-05

[Questions?](#)[Print this page](#)[Terms of Use](#)[Page Top](#)

© 2016 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2016 UL LLC".