



UTHV.S35734 Heat-actuated Devices for Special Application

[Page Bottom](#)

Heat-actuated Devices for Special Application

[See General Information for Heat-actuated Devices for Special Application](#)

EUROFYRE LIMITED

S35734

Unit C1 Knowle Village Business Park, Mayles Lane
Hampshire, PO17 5DY UNITED KINGDOM

Fixed temperature line type heat detector cables for indoor/outdoor use, Model(s) FLD105 (rated 105 C/221 F)(a)

FLD105N (rated 105 C/221 F)(b)

FLD185 [rated 185° C (365° F)]

FLD68(rated 68 C/155 F)(a), FLD68N(rated 68 C/155 F)(b), FLD88 (rated 88 C/190 F)(a), FLD88N (rated 88 C/190F)(b)

(a) - Distance between lines of heat detecting cable on smooth ceilings with large bays shall not be more than 35 ft. Distance between heat detecting cable from any wall or partition shall not be more than 17.5 ft.

(b) - Distance between lines of heat detecting cable on smooth ceilings with large bays shall not be more than 15 ft. Distance between heat detecting cable from any wall or partition shall not be more than 7.5 ft.

Note - Intended to be connected to a UL Listed control unit. Models are also complimentary Listed as a heat-automatic fire detector (UQGS).

[Last Updated](#) on 2016-02-05

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2016 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2016 UL LLC".